



TEST REPORT

Send To: 3E360
STOPAQ EUROPE B.V.
GASSELTERSTRAAT 20
9503 JB STADSKANAAL
THE NETHERLANDS
Attn: MR. J. F. DODDEMA

Customer: 3E360
STOPAQ EUROPE B.V.
GASSELTERSTRAAT 20
9503 JB STADSKANAAL
THE NETHERLANDS
Attn: MR. J. F. DODDEMA


Plant: 3E362
STOPAQ EUROPE B.V.
GASSELTERSTRAAT 20
9503 JB STADSKANAAL
THE NETHERLANDS
Attn: MR. M. NOOREN

Product: Stopaq FN2100
Trade Designation : Stopaq FN2100
Test Type: QQ - Qualification Testing

Thank you for having your product tested by NSF.

The enclosed report details the result of the testing performed on your product. Your program representative will be contacting you in the near future if there are any remaining issues concerning the status of this product.

Please do not hesitate to contact us if you have any immediate questions pertaining to your product.

Reviewer: 
Clifton Mclellan - Director, Toxicology Services

Status: **Pass**

CC: Program: 261 - DWA Std. 61 (Health Effects Testing)
Program Rep CHRISTIE MILLER
Region: 02 - Europe
PA Project: 232826

General Information

Standard: 061 - DRINKING WATER SYSTEM COMPONENTS - HEALTH EFFECTS

Class Function - JASM/PTM

DCC Number / Tracking ID - IA16246

Sample Description - Stopaq FN2100

Trade Designation - Stopaq FN2100

Sample Id: **S-0000314690**
 Description: Stopaq FN2100, Sample exposed at 23C and pH 5
 Sampled Date: 10/08/2006
 Received Date: 09/14/2006

Normalization Information:							
Date exposure completed:	08-OCT-2006	Calculated N1:	0.0070000	Field Exposure Time:	24 hours	Lab Exposure Time	24 hours
Field Surface Area:	0.1 in2	Lab Surface Area:	58 in2	Calculated N2:	1.00	Calculated N4:	1.000
				Constant N2:	1	Misc. Factor:	1
Field Static Volume:	1 L	Lab Static Volume:	4.18 L				
				Calculated NFm:	1.00		
Compound Reference Key: SPAC							

Testing Parameter	Sample	Control	Result	Normalized Result	Units
Chemistry Lab					
Aluminum in Drinking Water by ICPMS (Ref: EPA-200.8)					
Aluminum	130	ND(10)	130	0.92	ug/L
Total Arsenic in Drinking Water by ICPMS (Ref: EPA-200.8)					
Arsenic	ND(1)	ND(1)	ND(1)	ND(0.007)	ug/L
Barium in Drinking Water by ICPMS (Ref: EPA-200.8)					
Barium	5	2	3	0.02	ug/L
Beryllium in Drinking Water by ICPMS (Ref: EPA-200.8)					
Beryllium	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Bismuth in Drinking Water by ICPMS (Ref: EPA-200.8)					
Bismuth	ND(1)	ND(1)	ND(1)	ND(0.007)	ug/L
Cadmium in Drinking Water by ICPMS (Ref: EPA-200.8)					
Cadmium	ND(0.3)	ND(0.3)	ND(0.3)	ND(0.002)	ug/L
Chromium in Drinking Water by ICPMS (Ref: EPA-200.8)					
Chromium	ND(1)	ND(1)	ND(1)	ND(0.007)	ug/L
Copper in Drinking Water by ICPMS (Ref: EPA-200.8)					
Copper	ND(2)	ND(2)	ND(2)	ND(0.01)	ug/L
Mercury in Drinking Water by ICPMS (Ref: EPA-200.8)					
Mercury	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Nickel in Drinking Water by ICPMS (Ref: EPA-200.8)					
Nickel	ND(1)	ND(1)	ND(1)	ND(0.007)	ug/L
Lead in Drinking Water by ICPMS (Ref: EPA-200.8)					
Lead	ND(1)	ND(1)	ND(1)	ND(0.007)	ug/L
Antimony in Drinking Water by ICPMS (Ref: EPA-200.8)					
Antimony	ND(0.6)	ND(0.6)	ND(0.6)	ND(0.004)	ug/L
Selenium in Drinking Water by ICPMS (Ref: EPA-200.8)					
Selenium	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L

Testing Parameter	Sample	Control	Result	Normalized Result	Units
Chemistry Lab (Cont'd)					
Tin in Drinking Water by IPC/MS (Ref: EPA-200.8)					
Tin	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Strontium in Drinking Water by ICPMS (Ref: EPA-200.8)					
Strontium	70	31	39	0.3	ug/L
Thallium in Drinking Water by ICPMS (Ref: EPA-200.8)					
Thallium	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Zinc in Drinking Water by ICPMS (Ref: EPA-200.8)					
Zinc	21	21	ND(10)	ND(0.07)	ug/L
Silver in Water by ICP/MS (Ref: EPA-200.8)					
Silver	ND(1)	ND(1)	ND(1)	ND(0.007)	ug/L

Sample Id: **S-0000314691**
Description: Stopaq FN2100, Sample exposed at 23C and pH 10
Sampled Date: 10/08/2006
Received Date: 09/14/2006

Normalization Information:							
Date exposure completed:	08-OCT-2006	Calculated N1:	0.0070000	Field Exposure Time:	24 hours	Lab Exposure Time	24 hours
Field Surface Area:	0.1 in2	Lab Surface Area:	58 in2	Calculated N2:	1.00	Calculated N4:	1.000
				Constant N2:	1	Misc. Factor:	1
Field Static Volume:	1 L	Lab Static Volume:	4.25 L				
				Calculated NFm:	1.00		
Compound Reference Key: SPAC							

Testing Parameter	Sample	Control	Result	Normalized Result	Units
Chemistry Lab					
Aluminum in Drinking Water by ICPMS (Ref: EPA-200.8)					
Aluminum	260	230	35	0.26	ug/L
Total Arsenic in Drinking Water by ICPMS (Ref: EPA-200.8)					
Arsenic	ND(1)	ND(1)	ND(1)	ND(0.007)	ug/L
Barium in Drinking Water by ICPMS (Ref: EPA-200.8)					
Barium	3	ND(1)	3	0.02	ug/L
Beryllium in Drinking Water by ICPMS (Ref: EPA-200.8)					
Beryllium	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Bismuth in Drinking Water by ICPMS (Ref: EPA-200.8)					
Bismuth	ND(1)	ND(1)	ND(1)	ND(0.007)	ug/L
Cadmium in Drinking Water by ICPMS (Ref: EPA-200.8)					
Cadmium	ND(0.3)	ND(0.3)	ND(0.3)	ND(0.002)	ug/L
Chromium in Drinking Water by ICPMS (Ref: EPA-200.8)					
Chromium	ND(1)	ND(1)	ND(1)	ND(0.007)	ug/L
Copper in Drinking Water by ICPMS (Ref: EPA-200.8)					
Copper	ND(2)	ND(2)	ND(2)	ND(0.01)	ug/L
Mercury in Drinking Water by ICPMS (Ref: EPA-200.8)					
Mercury	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Nickel in Drinking Water by ICPMS (Ref: EPA-200.8)					
Nickel	ND(1)	ND(1)	ND(1)	ND(0.007)	ug/L

Testing Parameter	Sample	Control	Result	Normalized Result	Units
Chemistry Lab (Cont'd)					
Lead in Drinking Water by ICPMS (Ref: EPA-200.8)					
Lead	ND(1)	ND(1)	ND(1)	ND(0.007)	ug/L
Antimony in Drinking Water by ICPMS (Ref: EPA-200.8)					
Antimony	ND(0.6)	ND(0.6)	ND(0.6)	ND(0.004)	ug/L
Selenium in Drinking Water by ICPMS (Ref: EPA-200.8)					
Selenium	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Tin in Drinking Water by IPC/MS (Ref: EPA-200.8)					
Tin	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Strontium in Drinking Water by ICPMS (Ref: EPA-200.8)					
Strontium	23	24	ND(1)	ND(0.007)	ug/L
Thallium in Drinking Water by ICPMS (Ref: EPA-200.8)					
Thallium	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Zinc in Drinking Water by ICPMS (Ref: EPA-200.8)					
Zinc	19	19	ND(10)	ND(0.07)	ug/L
Silver in Water by ICP/MS (Ref: EPA-200.8)					
Silver	ND(1)	ND(1)	ND(1)	ND(0.007)	ug/L

Sample Id: **S-0000314692**
Description: Stopaq FN2100, Sample exposed at 23C and pH 8
Sampled Date: 10/08/2006
Received Date: 09/14/2006

Normalization Information:

Date exposure completed:	08-OCT-2006	Calculated N1:	0.0070000	Field Exposure Time:	24 hours	Lab Exposure Time	24 hours
Field Surface Area:	0.1 in2	Lab Surface Area:	58 in2	Calculated N2:	1.00	Calculated N4:	1.000
				Constant N2:	1	Misc. Factor:	1
Field Static Volume:	1 L	Lab Static Volume:	4.12 L				
				Calculated NFm:	1.00		

Compound Reference Key: SPAC

Testing Parameter	Sample	Control	Result	Normalized Result	Units
Chemistry Lab					
Semivolatle Compounds, Base/Neutral/Acid 625 Scan, Data Workup					
No Compounds Detected	ND(4)	Complete	ND(4)	ND(0.03)	ug/L
Semivolatle Compounds, Base/Neutral/Acid Target 625, Data Workup					
Nitrosodimethylamine (N-)	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
N-Nitrosomethylethylamine	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Nitrosodiethylamine (N-)	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Cyclohexanone	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Phenol	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Aniline	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
2-Chlorophenol	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
3-Cyclohexene-1-carbonitrile	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
2-Ethylhexanol	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Benzyl alcohol	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
2-Methylphenol (o-Cresol)	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L

Testing Parameter	Sample	Control	Result	Normalized Result	Units
Chemistry Lab (Cont'd)					
4-Methylphenol (p-Cresol)	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
N-Nitrosopyrrolidine	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
N-Nitrosodi-n-propylamine	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Acetophenone	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
N-Nitrosomorpholine	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
2-Phenyl-2-propanol	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
N-Nitrosopiperidine	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Triethylphosphate	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Isophorone	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
2,4-Dimethylphenol	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Naphthalene	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Benzothiazole	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
N-Nitrosodi-n-butylamine	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
p-tert-Butylphenol	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Methylnaphthalene, 2-	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
1(3H)-Isobenzofuranone	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Benzyl alcohol, a,a-dimethyl-p-isopropyl-	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
1,1'-(1,3-Phenylene)bis ethanone	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Dimethylphthalate	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
1,1'-(1,4-Phenylene)bis ethanone	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Benzenedimethanol, a,a,a',a'-tetramethyl-1,3-	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Acenaphthylene	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Benzenedimethanol, a,a,a',a'-Tetramethyl-1,4-	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
2,4-Di-tert-butylphenol	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Dimethyl terephthalate	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Acenaphthene	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Ethyl-4-ethoxybenzoate	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Diethyl Phthalate	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Fluorene	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Nitrosodiphenylamine (N-)	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Phenanthrene	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Anthracene	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Dibutyl phthalate	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Fluoranthene	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Pyrene	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Butyl benzyl phthalate	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Benzo(a)anthracene	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Di(2-ethylhexyl)phthalate	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Di(2-ethylhexyl)adipate	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Chrysene	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Di-n-octylphthalate	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Benzo(b)fluoranthene	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Benzo(k)fluoranthene	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Benzo(a)pyrene (PAH)	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Dibenzo(a,h)anthracene	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L

Testing Parameter	Sample	Control	Result	Normalized Result	Units
Chemistry Lab (Cont'd)					
Indeno(1,2,3-cd)pyrene	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Benzo(g,h,i)perylene	ND(4)	ND(4)	ND(4)	ND(0.03)	ug/L
Polynuclear Aromatic Hydrocarbons EPA 525.2					
Acenaphthene	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Acenaphthylene	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Anthracene	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Benzo(a)Anthracene	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Benzo(a)Pyrene	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Benzo(b)Fluoranthene	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Benzo(g,h,i)Perylene	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Benzo(k)Fluoranthene	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Chrysene	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Dibenzo(a,h)Anthracene	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Fluoranthene	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Fluorene	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Indeno(1,2,3,-c,d)Pyrene	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Naphthalene	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Phenanthrene	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Pyrene	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.001)	ug/L
Volatiles: Unregulated VOC's by EPA 502.2					
Dichlorodifluoromethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Chloromethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Vinyl Chloride	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Bromomethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Chloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Trichlorofluoromethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Trichlorotrifluoroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
1,1-Dichloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Methylene Chloride	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
trans-1,2-Dichloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
1,1-Dichloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
2,2-Dichloropropane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
cis-1,2-Dichloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Chloroform	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Bromochloromethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
1,1,1-Trichloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
1,1-Dichloropropene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Carbon Tetrachloride	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
1,2-Dichloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Trichloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
1,2-Dichloropropane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Bromodichloromethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Dibromomethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
cis-1,3-Dichloropropene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
trans-1,3-Dichloropropene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L

Testing Parameter	Sample	Control	Result	Normalized Result	Units
Chemistry Lab (Cont'd)					
1,1,2-Trichloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
1,3-Dichloropropane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Tetrachloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Chlorodibromomethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Chlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
1,1,1,2-Tetrachloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Bromoform	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
1,1,1,2,2-Tetrachloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
1,2,3-Trichloropropane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
1,3-Dichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
1,4-Dichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
1,2-Dichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Carbon Disulfide	ND(1)	ND(1)	ND(1)	ND(0.007)	ug/L
Methyl-tert-Butyl Ether (MTBE)	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Methyl Ethyl Ketone	ND(5)	ND(5)	ND(5)	ND(0.04)	ug/L
Methyl Isobutyl Ketone	ND(5)	ND(5)	ND(5)	ND(0.04)	ug/L
Toluene	0.7	ND(0.5)	0.7	0.005	ug/L
Ethyl Benzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
m+p-Xylenes	ND(1)	ND(1)	ND(1)	ND(0.007)	ug/L
o-Xylene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Styrene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Isopropylbenzene (Cumene)	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
n-Propylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Bromobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
2-Chlorotoluene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
4-Chlorotoluene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
1,3,5-Trimethylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
tert-Butylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
1,2,4-Trimethylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
sec-Butylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
p-Isopropyltoluene (Cymene)	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
1,2,3-Trimethylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
n-Butylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
1,2,4-Trichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Hexachlorobutadiene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
1,2,3-Trichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Naphthalene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Benzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L
Total Trihalomethanes	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.004)	ug/L

Testing Laboratories:

	<u>Flag</u>	<u>Id</u>	<u>Address</u>
All work performed at: (Unless otherwise specified)	→	NSF_AA	NSF International 789 Dixboro Road Ann Arbor MI 48105-0140 USA

References to Testing Procedures:

<u>NSF Reference</u>	<u>Parameter / Test Description</u>
C2023	Semivolatiles Compounds, Base/Neutral/Acid 625 Scan, Data Workup
C2024	Semivolatiles Compounds, Base/Neutral/Acid Target 625, Data Workup
C3032	Aluminum in Drinking Water by ICPMS (Ref: EPA-200.8)
C3035	Total Arsenic in Drinking Water by ICPMS (Ref: EPA-200.8)
C3038	Barium in Drinking Water by ICPMS (Ref: EPA-200.8)
C3041	Beryllium in Drinking Water by ICPMS (Ref: EPA-200.8)
C3043	Bismuth in Drinking Water by ICPMS (Ref: EPA-200.8)
C3046	Cadmium in Drinking Water by ICPMS (Ref: EPA-200.8)
C3052	Chromium in Drinking Water by ICPMS (Ref: EPA-200.8)
C3058	Copper in Drinking Water by ICPMS (Ref: EPA-200.8)
C3071	Mercury in Drinking Water by ICPMS (Ref: EPA-200.8)
C3095	Nickel in Drinking Water by ICPMS (Ref: EPA-200.8)
C3100	Lead in Drinking Water by ICPMS (Ref: EPA-200.8)
C3113	Antimony in Drinking Water by ICPMS (Ref: EPA-200.8)
C3115	Selenium in Drinking Water by ICPMS (Ref: EPA-200.8)
C3121	Tin in Drinking Water by IPC/MS (Ref: EPA-200.8)
C3122	Strontium in Drinking Water by ICPMS (Ref: EPA-200.8)
C3127	Thallium in Drinking Water by ICPMS (Ref: EPA-200.8)
C3135	Zinc in Drinking Water by ICPMS (Ref: EPA-200.8)
C4326	Polynuclear Aromatic Hydrocarbons EPA 525.2
C4416	Volatiles: Unregulated VOC's by EPA 502.2
C6430	Silver in Water by ICP/MS (Ref: EPA-200.8)

If the test description is preceded by an asterisk, *, the testing has been performed per NSF International Quality Assurance requirements but not independently audited to the current, released version of ISO 17025.